



Never compromise on quality!



PC500 RADLEAK

Leak Sealer for Domestic Central Heating Systems



PLUMBERS COMPLETE RANGE

Description:

A central heating internal leak sealer.

Uses

PC500 RADLEAK is used for sealing inaccessible leaks and weeping joints in sealed systems. Use of **RADLEAK** can help avoid costly repairs and it will not block the pump, valve or air vents.

Application

Introduce via the feed and expansion tank. Shake bottle well before use and use entire contents. Tie up ball valve in feed and expansion tank. Turn boiler off and locate drain down cock. Attach a hose to the drain cock and remove approx 10 litres of system water. Close off drain cock. Empty **RADLEAK** in to header tank. Untie ball valve and turn boiler on.

Vent the system as necessary to alleviate any trapped air. A soft seal will form over 24 hours, this will not cause any blockages in the system. Full effect will be achieved within 1-6 weeks.

Note: Do not mix this product with any other concentrated chemicals. It can be added to treated systems provided it is administered separately.

Limitations

DO NOT ADD TO PRIMATIC SYSTEM.

Container Size

1L plastic bottle.

Colour

Opaque liquid.

Shelf Life

36 months from date of manufacture when stored in original, sealed containers.

Storage Conditions

Store in cool, dry conditions in tightly sealed container. Do not allow to freeze.

Disposal of Containers

Do not leave empty containers where residue could be harmful to children, animals or the environment. Replace lids and remove any containers to a central disposal point in accordance with local regulations.

Health & Safety

Please refer to separate material safety data sheet for full handling, use and storage instructions. Keep out of reach of children. It is the users responsibility to determine suitability for use. If in doubt contact our Technical Department for advice.

Note: this information is for general guidance only, since site conditions and labour are beyond our control. It is recommended that users make their own tests to determine suitability.



Specification Summary

Appearance	Opaque liquid
Flammability	Non-flammable

Product Details:

Code:	BDPC500
Colour:	Opaque
Size:	1L
Barcode:	5060021367624



Part of the Bond It Plumbers Complete Range

The data presented in this leaflet are in accordance with the present state of our knowledge, but do not absolve the user from carefully checking all supplies immediately on receipt. We reserve the right to alter product constants within the scope of technical progress or new developments. The recommendations made in this leaflet should be checked by preliminary trials because of conditions during processing over which we have no control, especially where other companies raw materials are also being used. The recommendations do not absolve the user from the obligation of investigating the possibility of infringement of third parties rights and, if necessary clarifying the position.

Recommendations for use do not constitute a warranty, either expressed or implied, of the fitness or suitability of the products for a particular purpose.



Certificate Number:
6152
ISO 9001; ISO 14001;
ISO 45001

BOND IT
*Head Office: Unit G16 River Bank Way, Lowfields Business Park,
Elland, West Yorkshire HX5 9DN.
Telephone: +44 (0)1422 315300 Fax +44 (0)1422 315310
Email: salesuk@bonditgroup.com Website: www.bonditgroup.com*



V2 20/01/17
Supercedes: V1 30/07/09