



Never compromise on quality!



PC300 UNICLEAN

Universal Cleaner for New Central Heating Systems



PLUMBERS COMPLETE RANGE

Description:

A powerful universal cleaner and passivater for new central heating systems or systems up to 6 months old.

Uses

PC300 UNICLEAN is suitable for all metals including aluminium; no neutralisation required.

Application

Filling the system: Open systems should be dosed via the filling and expansion tank. Adequate draining from a low point is necessary to ensure product enters the system. Closed systems should be dosed via filling loop or a partially drained radiator. If the system is empty add at any suitable point prior to filling.

Cleaning: Circulate the system containing the cleaner for at least one hour. Warming the water by running the boiler on low will aid the process. Drain the system at all drain points and then flush through until water runs clear. When re-filling system dose with PC100 or 200 INHIBITOR.

Dosage: **PC300** should be dosed @ 1% of system for maximum performance. This is the volume of a system with a 14.5Kw Boiler (50,000 Btu/hr). Larger systems will require more cleaner pro rata. Overdosing will not cause any problems or detrimental affects to the system.

Please note: where a thermal storage appliance is fitted allowance must be made for the extra volume of primary water. The concentration can be checked with a conductivity metre.

Limitations

DO NOT ADD TO PRIMATIC SYSTEM.

Container Size

1L plastic bottle.

Colour

Pale orange liquid.

Shelf Life

12 months from date of manufacture in original, unopened containers.

Storage Conditions

Store in cool, dry conditions in tightly sealed container. Do not allow to freeze.

Disposal of Containers

Do not leave empty containers where residue could be harmful to children, animals or the environment. Replace lids and remove any containers to a central disposal point in accordance with local regulations.

Health & Safety

Please refer to separate material safety data sheet for full handling, use and storage instructions. Keep out of reach of children. It is the users responsibility to determine suitability for use. If in doubt contact our Technical Department for advice.

Note: this information is for general guidance only, since site conditions and labour are beyond our control. It is recommended that users make their own tests to determine suitability.

Specification Summary

Appearance	Pale orange liquid
Odour	None
Specific Gravity	Approx 1
pH	Approx 4-5
Vapour Pressure	2.14 KPa (25°C)



Product Details:

Code:	BDPC300
Colour:	Pale Orange
Size:	1L
Barcode:	5060021367488



Part of the Bond It Plumbers Complete Range

The data presented in this leaflet are in accordance with the present state of our knowledge, but do not absolve the user from carefully checking all supplies immediately on receipt. We reserve the right to alter product constants within the scope of technical progress or new developments. The recommendations made in this leaflet should be checked by preliminary trials because of conditions during processing over which we have no control, especially where other companies raw materials are also being used. The recommendations do not absolve the user from the obligation of investigating the possibility of infringement of third parties rights and, if necessary clarifying the position.

Recommendations for use do not constitute a warranty, either expressed or implied, of the fitness or suitability of the products for a particular purpose.



Certificate Number:
6152
ISO 9001; ISO 14001;
ISO 45001

BOND IT
Head Office: Unit G16 River Bank Way, Lowfields Business Park,
 Elland, West Yorkshire HX5 9DN.
Telephone: +44 (0)1422 315300 **Fax** +44 (0)1422 315310
Email: salesuk@bonditgroup.com **Website:** www.bonditgroup.com



V3 03/12/12
 Supercedes: V2